COAXIAL SURGE PROTECTOR DEVICE, GDT technology up to 1.0 GHz, with GDT 470 V

3401.17.0056

Properties

- Broadband frequency operation from DC to 1 GHz
- Gas discharge tube replaceable and included
- DC/AC remote powering via coaxial same cable
- Surge current handling capability 30 kA once and 20 kA multiple
- Semper self-extinguishing functionality optional









Product configuration	
Main path connectors	Port 1: unprotected, N jack (female)
	Port 2: protected, N jack (female)
Mounting and grounding	MH12 (bulkhead mounting)
Side of bulkhead	protected side

Interface and material data	
Housing material / plating	Brass / SUCOPLATE (R) Plating
Center contact, material / plating	Port 1: Copper Beryllium Alloy / Gold Plating (without Nickel underplating)
	Port 2: Copper Beryllium Alloy / Gold Plating (without Nickel underplating)

Electrical data		
Impedance	50 Ω	
Frequency frame	0 MHz to 1000 MHz	
Return loss typical	26.44 dB	
Insertion loss typical	0.1 dB	
CW power frame	586 W	
Surge current handling capability	30 kA single, 20 kA multiple (test pulse 8/20 μs)	

Electrical remarks	
Gas tube	Yes DC, GDT included, replaceable, 9071.99.0550 (470 V)



COAXIAL SURGE PROTECTOR DEVICE, GDT technology up to 1.0 GHz, with GDT 470 V 3401.17.0056

Mechanical data	
Weight	109 g
Mating cycles	500
Environmental data	
Operation temperature	-40 °C 85 °C
Storage temperature	-40 °C 85°C
Ingress protection (IP Rating)	IP67
Thermal shock according	MIL-STD-202, Method 107, Cond. B
Vibration according	MIL-STD-202, Method 204, Cond. D
Moisture resistance according	MIL-STD-202, Method 106
Comment	
	Replacement parts: - Mounting washer nut set 9075.99.0035 - Gas discharge tube holder 9075.99.0112 - Gas discharge tube 9071.99.0550, (470 V)
Ordering Information Table	
Item number	Item description

3401.17.0056

HUBER+SUHNER is certified by ISO 9001, ISO 14001, ISO 45001, IATF 16949, AS/EN 9100 and ISO/TS 22163-IRIS. Waiver: Facts and figures herein are for information only and do not represent any warranty of any kind. DOCUMENT PIM-P2031 / Date of publication: 06.03.2024 / uncontrolled copy

84145588

